



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

March 16, 2007

CROMAGLASS CORPORATION  
FRANK MOLTZ  
PO BOX 3215  
WILLIAMSPORT PA 17701

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED  
Manufacturer: CROMAGLASS CORPORATION  
Product Name: WASTEWATER TREATMENT SYSTEM  
Model Number(s): CA-5 (500 GPD)  
Product File No: 20030569

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2009.

This approval supersedes the approval issued on July 3, 2000, under product file number 20000746.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000746.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- A minimum 2" diameter vent must be provided on the building sewer within 12" of the connection to the tank.
- This product is recognized to treat a maximum of 1.0 pound of BOD5 per day at a maximum daily wastewater flow of 500 gallons per day.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov